



NOTE:
 ENSURE STOTHERM PANELS ARE SUPPORTED BY A MIN. OF 2/STUDS. VERTICAL CONTROL JOINTS ARE REQUIRED AT 20 LINEAL METRES MAX. OR AT ENGINEERED FRAMING EXPANSION JOINTS and at DISSIMILAR MATERIAL JUNCTIONS. SET STO CONTROL JOINT AND REMOVE TAB CAREFULLY AS SOON AS THE JOINT IS SET TO AVOID CRACKS

SCALE: 1:2

STOTHERM SYSTEM	STOTHERM INSULATED FACADE SYSTEM	ST 305
	VERTICAL CONTROL JOINT	2017