



REFER TO E2/AS1 FIG. 17 A,B,C & D INCLUDING SECTION 9.1.10
MIN.THRESHOLD 100mm FROM FLOOR TO FINISHED DECK

NOTE: ADJUST 35mm TO ALLOW FOR SELECTED TILES AS REQUIRED, UNDER
DOOR TRIM BY BUILDER

SCALE 1:5

STOTHERM SYSTEM	STOTHERM INSULATED FACADE SYSTEM	ST 407
	ENTRY DOOR/DECK THRESHOLD DETAIL	2017