



NOTE:

REFER E2/AS1 Fig.16 FOR FLASHING REQUIREMENTS. PROVIDE 6-8mm WIDE SEALANT JOINT AT CLADDING/SADDLE FLASHING JUNCTION.

50mm MIN. SET DOWN FROM FLOOR OR THRESHOLD FOR CANTILEVERED SLATTED DECKS

STOTHERM SYSTEM	STOTHERM INSULATED FACADE SYSTEM	ST 509
	CANTILEVERED SLATTED DECK	2017