



NOTE:
 BACK FLASHING IS REQUIRED BEHIND FASCIA AND PANEL JUNCTION 50mm MIN. COVER.
 FOR DURABILITY OF FLASHING REFER TABLE 20 NZBC E2/AS1 DOCUMENT.
 ROOF UNDERLAY OMITTED FOR CLARITY.

SCALE 1:10

STOTHERM SYSTEM	STOTHERM INSULATED FACADE SYSTEM	ST 606
	GUTTER/WALL APRON FLASHING JUNCTION	2017