



1. SHEET JOINTS MUST NOT COINCIDE WITH EDGE OF JOINERY UNLESS A CONTROL JOINT IS TO BE FORMED.
2. ALL SHEET EDGES SHALL LINE THROUGH AND BE SUPPORTED BY A FRAMING MEMBER.
3. INSTALL SHEETS AS PER DETAILS USING NOMINAL 20x45mm H3.1 TIMBER CAVITY BATTENS
4. STAGGER VERTICAL SHEET JOINTS AT INTERSTOREY JOINT.
5. ALL SHEET EDGES SHALL BE A TIGHT BUTT FIT MESHERD WITH 100mm JOINTING TAPE IN BASECOAT.
6. FLASHING AS FOLLOWS
 - HORIZONTAL STO uPVC 12mm CONTROL JOINT AT INTERSTOREY JUNCTIONS
 - STO 8mm VERTICAL CONTROL JOINTS @ 5.4m crs max.
 - INTER-STOREY DRAINED JOINT EVERY THIRD STOREY

SCALE: N.T.S

STOLITE SYSTEM	STOLITE CONSTRUCTION SYSTEM STOLITE SHEET LAYOUT	SL 300
		2017

The information contained on this page is based on our experience and research at the date of issue. The detail is for use by Registered Architects, Licensed Designers or Chartered Engineers to assist in developing project details using Sto Systems. Stoanz Ltd reserve the right to alter or update information at any time without prior notice and it is the responsibility of the designer, project manager or Sto contractor to insure they have and use the current Sto details and specifications on site.