



AIRSEAL ON PEF ROD GAP
7.5-8mm APPROX.

WALL UNDERLAY RETURNED
INTO OPENINGS & FLASHING
TAPE CONTINUOUS ALONG
SILL MIN 100mm UP JAMBS &
50mm ONTO FACE OF WALL
UNDERLAY

TIMBER FRAMING
TO NZS 3604

INTERIOR LINING

PROPRIETARY
ALUM. WINDOW
JOINERY

FRAME BLOCK

JOINERY SUPPORT BAR
REQUIRE FOR
OPENINGS OVER 600mm

MS SEALANT

STO uPVC SILL FLASHING
FIX ONTO BACKERBOARD;
UNDER JAMBS

CAVITY BATTENS

6mm FIBRE CEMENT
SHEET

STOLITE RENDER SYSTEM

1. SEALANT IS APPLIED TO THE SILL AND JAMBS
2. uPVC SILL FLASHING TO BE PLACED UNDER JAMB FLASHING - CUT TABS OFF SILL APPROX 30mm EITHER END AND SLIP UNDER uPVC JAMB FLASHING
3. ALLOW 3mm GAP BETWEEN WINDOW JOINERY AND FIBRE CEMENT SHEET FOR STOLITE uPVC FLASHINGS

WARNING: SOME BRANDS OF ALUMINIUM JOINERY HAVE DRAINAGE VENTS IN THE BOTTOM EDGE OF THE SILL FLANGE. ENSURE DRAINAGE VENTS REMAIN CLEAR.

SCALE 1:2

STOLITE SYSTEM	STOLITE CONSTRUCTION SYSTEM	SL 401
	ALUMINIUM JOINERY - SILL DETAIL	2017