



NOTE:
REFER E2/AS1 Fig.16 FOR FLASHING REQUIREMENTS. PROVIDE 6-8mm
WIDE SEALANT JOINT AT CLADDING/SADDLE FLASHING JUNCTION.

50mm MIN. SET DOWN FROM FLOOR OR THRESHOLD FOR
CANTILEVERED SLATTED DECKS

SCALE 1:5

**STOLITE
SYSTEM**

**STOLITE CONSTRUCTION SYSTEM
CANTILEVERED SLATTED DECK**

SL 509

2017