



STOSTUCCO STAINLESS STEEL LATH

- BITUMINOUS UNDERLAY ATTACHED
- CARD BACKING TO REGULATE PLASTER
- DOUBLE 2.0M FIXING WIRES @ 150mm CTRS
- FIX WITH PRINTED SIDE OUT
- USE AIR POWERED 16gx 32mm STAPLES @ 150mm CTRS
- INSTALL PERPENDICULAR TO STUDS
- STRETCHER BOND PATTERN INSULATION
- OVERLAP BY ONE (1) SECTION HORIZONTALLY & TWO (2) VERTICALLY
- REMOVE ANY OVERLAPPING UNDERLAY or CARD
- WIRE JOINS OFF STUDS

SCALE 1:20

| | | |
|-----------------------------|---|---------------|
| STOSTUCCO SYSTEM | STOSTUCCO CONSTRUCTION SYSTEM | SS 007 |
| | STOSTUCCO S/S LATH SHEET INFORMATION | 2014 |

The information contained in this detail is based on our experience and testing and represents the latest information available at the date of issue. This detail is intended for use by the design professional and users of Sto products to assist in developing specific project details to be used in conjunction with a Sto Specification. We reserve the right to alter or update information at any time without prior notice & it is the responsibility of the specifier and/or the project manager to insure that they have the current Sto details and specifications.