



TIMBER FRAMING TO NZS 3604

WALL UNDERLAY MEETING REQUIREMENTS OF E2/AS1

EXTRA CAVITY BATTENS OR STRAPPING TAPE BETWEEN 600mm CTR FRAMING FOR FLEXIBLE UNDERLAY TO STOP INSULATION ENCROACHING INTO CAVITY

- STOPOREN RENDER SYSTEM**
- S-PROTECT WS 205 SEALER
 - POREN RENDER
 - MESH REINFORCEMENT RENDER
 - STOPLEX W SEALER
 - STOLIT COLOURED FINISHING RENDER
 - STOCOLOR PAINT

PANEL TO OVERHANG FOUNDATION 50mm

DPC

CONCRETE SLAB

50mm panel overhang

STOPOREN PANEL

POREN PANEL ADHESIVE ON PANEL JOINTS

STO ADJUSTABLE FOOT TRAY MIN. 50mm PAST BOTTOM PLATE OR SUBFRAME. VENTILATION MIN 1000sq mm PER LINEAL METRE

NOTE: 600mm FRAMING
 FIXINGS AT 300mm CENTRES GENERALLY ON FRAMING 150mm FROM PANEL EDGE WITH ONE FIXING BETWEEN STUDS ON THE BOTTOM PLATE ON FRAMING @ 600mm CTRS max.
 REFER TO FOUNDATION DETAILS FOR SPECIFIC FIXING LAYOUT

SCALE 1:20

STOPOREN FACADE	STOPOREN FACADE SYSTEM	PP 100
	CAVITY BATTEN SETOUT (600ctrs) - ISOMETRIC	2020

The information contained on this page is based on our experience and research at the date of issue. The detail is for use by Registered Architects, Licensed Designers or Chartered Engineers to assist in developing project details using Sto Systems. Stoanz Ltd reserve the right to alter or update information at any time without prior notice and it is the responsibility of the designer, project manager or Sto contractor to insure they have and use the current Sto details and specifications on site.