



NOTE:
 REFER E2/AS1 Fig.16 FOR FLASHING REQUIREMENTS. PROVIDE 6-8mm
 WIDE SEALANT JOINT AT CLADDING/SADDLE FLASHING JUNCTION.

50mm MIN. SET DOWN FROM FLOOR OR THRESHOLD FOR
 CANTILEVERED SLATTED DECKS

SCALE 1:5

STOPOREN FACADE	STOPOREN FACADE SYSTEM	PP 509
	CANTILEVERED SLATTED DECK	2020